

Plan Submittal Checklist

Health Care

1) Code Footprint

- a) Printed on 11 x 17 paper
- b) Project must be designed and comply with NFPA 101 2000 Life Safety Code. This must be listed in the Code Analysis section along with all local jurisdiction codes.
- c) Active and Passive Fire Protection features must be listed.
- d) Occupancy Load must be included.
- e) Location of the Fire Department Connection must be provided.
- f) Location and number of Hydrants or Water Supply must be clearly indicated.
- g) Required Fire Flow and the Available Fire flow must be provided.
- h) Classification of Hazards must be listed.
- i) Fire Department Access/Fire Lanes, width, height, length, turnaround radius and surface material
- j) The number of exits and the widths must be clearly shown.
- k) Area of remodel, renovation, addition to building etc. must be identified.
- l) Must be sealed, signed and dated by a Kansas licensed Architect or Engineer.

2) C.2.2 Form

- a) Found at www.accesskansas.org/firemarshal
- b) In left hand column click on forms, scroll down the page to locate the form.
- c) Correspondence of project acceptance or denial will be sent to whoever is placed in the Owner's Representative section.

3) C.2.2.A Form

- a) Found at www.accesskansas.org/firemarshal
- b) In left hand column click on forms, scroll down the page to locate the form.

4) Fire Alarm Plans

- a) Must be designed, installed and comply to with NFPA 72 1998 edition and listed in the Code Analysis section
- b) Must include battery Calculations
- c) Must include device spec sheets
- d) Must be sealed, signed and dated by a Kansas licensed Engineer

5) Sprinkler System Plans

- a) Must be designed, installed and comply with the NFPA 13 1999 edition and listed in the Code Analysis section
- b) Must include hydraulic Calculations
- c) Must include flow Chart
- d) Must be sealed, signed and dated by Kansas licensed Engineer
- e) Sprinklers located in sprinkler legend must match the number of sprinklers located on drawing.

6) Notice for Final Inspection

- a) A 30 day written notice must be submitted to either KDOA or KDHE as to the date on which 100% of the construction will be completed. KDOA or KDHE will then submit a notice to the Kansas State Fire Marshal's Office to schedule a final inspection.